



JAMES BOWIE HIGH SCHOOL

Friday, January 17, 2020

Dear James Bowie High School Families,

At approximately 11:00 a.m., all E Hall classrooms were evacuated for about 45 minutes because of a strong smell of gas in one of the classrooms. The Austin ISD School Resource Officers (SRO) on campus immediately contacted the Austin Fire Department.

Fire department officials investigated and found a leak on one of the valves in the science lab. The Bowie gas main was shut off. Once AFD Special Operations and AISD PD determined the area was safe, students and staff returned to their classes.

If you have any questions or concerns, please do not hesitate to contact the office at 512-414-5247. As always, we thank you for your support of James Bowie High School.

Sincerely,

Mark Robinson
Principal
James Bowie High School